

# Installation and Startup Guide

Digital Pressure Gauge & Switch

Revision 1.0

Document 2052



Anderson Instrument Co., Inc. 156 Auriesville Rd. ~ Fultonville, NY 12072

n

Phone: 518-922-5315 ~ Fax: 518-922-8997

Reach us on the World Wide Web www.andinst.com

### **PRODUCT DESCRIPTION**

The Anderson Digital Pressure Gauge platform is designed specifically for monitoring critical pressures in sanitary applications. The product line was developed to address several trends relative to performance, safety, and readability criteria of our core customers. The Anderson Digital Pressure Gauge provides a battery-powered, local display of pressure that is 6 times more accurate than its mechanical counterpart. Additionally, this product has 3 times the over-range capacity and 5-10 times the resolution of traditional mechanical pressure indicators. The switch version includes 2 fully adjustable switches with low-voltage relay outputs for simple control and/or alarming applications.

## SPECIFICATIONS

<u>Electrical</u>

p.....

Performance		rower:	2 AA replaceable batteries with one-year minimum expected life with industrial arade
Accuracy:	±0.2% of URL (upper range limit) Complies with ASME B40.7-1998		batteries (gauge only); 9-30 Volts external DC power (with switches) with battery back-up of
Repeatability:	±0.06% URL		non-volatile programmea values.
Hysteresis:	±0.07% URL	Relay Outputs (Switch only):	Two (2) independent, adjustable setpoint relays: One amp contact rating at 24 volts DC, SPST; Contacts open with no power to unit (failsafe) each programmable to close above or below setpoint.
Linearity:	±0.07% URL		
Temperature stability:	±0.16% / 10°F change in process or ambient		
Over-range Capacity:	2X URL	<u>Mechanical</u>	
Operational		Display:	LCD, with 0.9" height
Process Temp Limits:	-4° to 127°C (25° to 260°F) continuous	Wetted Material:	316 "L" Stainless Steel, welded and polished to max $R_a = 8$ microinches (0.2 microns) for EP and max $R_a = 25$ microinches for EN.
Ambient Temp Limits:	4° to 49°C (40° to 120°F)		
Engineering Units:	Programmable by user, see matrix for selections.	Housing:	304 Stainless Steel, welded
		Lens:	Polysulphone
Compound ranges:	Full Vacuum to selected positive pressure. If set to "HG, display reads in "HG when in the vacuum range and PSIG when there is positive pressure.	Approvals and Documentation	
		Sanitary: Meet current ASME BPE-2002 standards; Authorized to display the 3-A Symbol, Third Party Verified.	
Min / Max Pressure:	Captured and stored in non-volatile memory, may be cleared via tamper- resistant toggle.	PED: Complies with the Pressure Equipment Directive relative to Sound Engineering Practices	
		Electrical: Tested to IEC 61326 Standard for Emissions and Immunity in Industrial locations.	
		Enclosure: Meets or exceeds requirements for NEMA 4X.	
		Hazardous Locations: UL for Intrinsically Safe requirements pending.	
		Material, Conformance and Calibration: Certificates provided with product, also available on-line using serial number (applies to EP only).	

## **USER INTERFACE GUIDE**

The Anderson Digital Pressure Gauge and Switch is factory calibrated and configured to the range and units specified by the order matrix number. Displayed pressure units, alarm setpoint, hysteresis and action values may be easily modified by the user. The calibrated range of the gauge, however, may not be modified in the field. Gauge calibration may be performed through the following User Interface Guide.

The Digital Pressure Gauge configuration parameters are sorted into three different user modes, and are accessible via the three switches located under the protection of the removable gauge back. To access the switches simply remove the two screws, and the cover with gasket. While the cover is removed, do not allow moisture to enter the gauge housing.



## **BATTERY REPLACEMENT**

Two user replaceable AA batteries are located under the cover of the removable gauge back. With alkaline batteries typical expected life is 12 months. This may vary depending on the dynamics of the system being measured.

#### IMPORTANT

A three bar battery status indicator is provided on the user display. As batteries discharge bars will drop off. Shortly after the display of a single bar the entire display will blink. It is strongly recommended that batteries be replaced or removed at or prior to the single bar level. Continued operation while display is blinking may result in lost calibration and require factory recalibration. Batteries may be removed and unit stored indefinitely without loss of calibration.

### **ALARM SETPOINT PROGRAMMING**

(MODE Switch in the UP position)



### **CALIBRATION / CONFIGURATION PROGRAMMING**

(MODE Switch in the DOWN position)



## **RELAY WIRING (DIGITAL PRESSURE SWITCH ONLY)**



Digital Pressure Switch must be externally powered to utilize relays.

### **ORDERING MATRIX**



01 Anderson Instrument Co.